

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20150130-R25183  
**Report Reference** R25183-20120706  
**Issue Date** 2015-January-30

**Issued to:** PRIHODA S R O  
ZA RADNICI 46  
53901 HLINSKO CZECH REPUBLIC

**This is to certify that  
representative samples of**

DISTRIBUTION DEVICES, AIR  
PMI / NMI / PMS FABRIC DUCT/DIFFUSER

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**


UL723, Standard for Surface Burning Characteristics for  
Building Materials, UL2518  
CAN/ULC-S102.2-10, Standard method of test for surface  
burning characteristics of flooring, floor covering, and  
miscellaneous materials and assemblies

**Additional Information:**


See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and

"US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)



# CERTIFICATE OF COMPLIANCE

Certificate Number 20150130-R25183 |  
Report Reference R25183 |  
Issue Date 2015-January-30 |

This is to certify that representative samples of the product as specified on this certificate were tested according to the current ULC requirements.

Fabrics Listed as to surface burning characteristics in accordance with CAN/ULC-S102.2 as indicated.

Material Details	Classification or Rating	
	Flame Spread	Smoke Developed
100% Polyester fabric designated "NMI"	0	45
100% Polyester fabric designated "PMS"	10	50
100% Polyester fabric designated "PMI"	0	50



John Arrabito, Vice President and Treasurer

UNDERWRITERS LABORATORIES OF CANADA INC.

Any information and documentation involving ULC Mark services are provided on behalf of Underwriters Laboratories of Canada Inc. (ULC) or any authorized licensee of ULC. For questions, please contact a local ULC Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)

