



**TEXTILNÍ ZKUŠEBNÍ ÚSTAV, s.p.**  
**(TEXTILE TESTING INSTITUTE)**  
**Certification body for the certification of products**  
Václavská 237/6, 603 00 Brno, Czech Republic

issues

Client: **PŘÍHODA s.r.o., Za Radnicí 476, 539 01 Hlinsko v Čechách, Czech Republic**  
ID: 62024205

# TYPE CERTIFICATE

No. 19 – 072/1



Product: **Fabric NMI**  
textile material with antibacterial treatment, used in textile based ventilation  
- material composition: 100 % polyester  
- mass per unit area: 220 g.m<sup>-2</sup>, colour: white

This certificate shows the conformity of the products with the following technical specification:

- **EN ISO 20645:2004 Textile fabrics - Determination of antibacterial activity - Agar diffusion plate test** regarding to antibacterial of the antibacterial treatment – Article 10, Table No. 1
- **EN ISO 20743:2013 Textiles - Determination of antibacterial activity of textile products** regarding to antibacterial activity of the antibacterial treatment – Annex F, Table F. 1

**Based upon the acquired level of antibacterial activity it has been proved that the assessed sample produces good antibacterial efficiency – strong antibacterial activity.**

**Good antibacterial efficiency was detected on new NMI fabric  
and on NMI fabric after 10 cycles of washing 40°C.**


Certification system: Type testing.

The base for the Certificate is the Final Protocol No. COV/19/306 from 04.11.2019 issued by Certification Body Textile Testing Institute in Brno. Final Protocol is an inseparable part of the Certificate.



Certificate issued:  
Brno 04.11.2019  
Validity up to: 30.11.2022



  
Ing Svatava Horáčková  
Head of certification department