



**TEXTILNÍ ZKUŠEBNÍ ÚSTAV, s.p.**  
(TEXTILE TESTING INSTITUTE)  
Certification body for the certification of products  
Cejl 480/12, Zábřdovice, 602 00 Brno, Czech Republic



issues

Client: **PŘÍHODA s.r.o., Za Radnicí 476, 539 01 Hlinsko v Čechách, Czech Republic**  
ID: 62024205

## TYPE CERTIFICATE

No. 22 – 106/1

Product: **Fabric NMI**  
textile material with antibacterial treatment, used in textile based ventilation  
material composition: 100 % polyester; colour: grey

This certificate shows the conformity of the product with the following technical specification:

- **EN ISO 20645:2004 Textile fabrics - Determination of antibacterial activity - Agar diffusion plate test** regarding to antibacterial of the antibacterial treatment – Article 10, Table No. 1
- **EN ISO 20743:2021 Textiles - Determination of antibacterial activity of textile products** regarding to antibacterial activity of the antibacterial treatment – Annex F, Table F. 1
- **EN 14119:2003 Textiles - Testing of textiles - Evaluation of the action of microfungi**

**Based upon the acquired level of antibacterial activity it has been proved that the assessed sample produces good antibacterial efficiency – strong antibacterial activity.**

**Good antibacterial efficiency was detected on new fabric and on fabric after 10 cycles of washing 40°C.**

**High resistance to the microscopic fungi - mold has been proven.**

Certification system: Type testing.

The base for the Certificate is the Final Protocol No. COV/22/290-1 from 10.11.2022 issued by Certification Body Textile Testing Institute in Brno. Final Protocol is an inseparable part of the Certificate.



Certificate issued:  
Brno 11.11.2022  
Validity up to: 30.11.2025



Ing. Svatava Horáková  
Head of certification department