

**TEXTILNÍ ZKUŠEBNÍ ÚSTAV, s.p.**  
**Certifikační orgán pro certifikaci výrobků**  
Cejl 480/12, Zábrdovice, 602 00 Brno

vydává



Zadavatel: **PŘÍHODA s.r.o., Za Radnicí 476, 539 01 Hlinsko v Čechách**  
IČ: 62024205

## **CERTIFIKÁT TYPU**

**č. 23 – 021/1**

Výrobek: **Tkaninové potrubí a vyústky**  
varianty: **NLS, NMF, NMR, PMI, NMS, NMSre, PLS, PMS, PMSre, NMI**  
varianty: **tkaniny prodyšné, tkaniny se zátěrem (neprodyšné), tkaniny s antibakteriální úpravou, tkaniny antistatické**  
materiálové složení: 1) 100 % polyester s uhlíkovým vláknem (< 1%)  
100 % polyester s uhlíkovým vláknem (< 1%) + polyuretan  
2) 100 % polyester + polyuretan/  
100 % polyester recyklovaný + polyuretan  
3) 100 % polyester + polyvinylchlorid  
barva: bílá, žlutá, šedá, modrá, zelená, červená, černá a další

Tímto certifikátem se potvrzuje shoda výrobku v hodnoceném parametru s následující technickou specifikací

- **ČSN EN ISO 14644-1:2019 Čisté prostory a příslušná řízená prostředí – Část 1: Klasifikace čistoty vzduchu podle koncentrace částic (Tabulka 1 - Třídy čistoty vzduchu ISO podle koncentrace částic; třída 4).**

**Na základě dosažené úrovně hodnoceného parametru (množství uvolněných částic velikosti 0,5 a 1 µm) je materiál klasifikován do třídy ISO čistoty vzduchu č. 4**


Certifikační systém: zkoušení typu

Podkladem pro certifikát je závěrečný protokol č. COV/23/044-1 ze dne 29.05.2023 a č. COV/23/327 ze dne 03.11.2023 vydaný COV TZU v Brně. Závěrečné protokoly tvoří nedílnou součást tohoto certifikátu.




Certifikát vydán:  
v Brně dne 30.05.2023  
Aktualizace dne 06.11.2023  
Platnost do 31.05.2026



  
Ing. Svatava Horácková  
vedoucí certifikačního oddělení





**TEXTILNÍ ZKUŠEBNÍ ÚSTAV, s.p.**  
(TEXTILE TESTING INSTITUTE)  
**Certification body for the certification of products**  
Cejl 480/12, Zábrdovice, 602 00 Brno, Czech Republic

issues



Client: **PŘÍHODA s.r.o., Za Radnicí 476, 539 01 Hlinsko v Čechách, Czech Republic**  
ID: 62024205

## TYPE CERTIFICATE

**No. 23 – 021/1**

Product: **Fabric Air Ducting & Diffuser**  
variants: **NLS, NMF, NMR, PMI, NMS, NMSre, PLS, PMS, PMSre, NMI**  
variants: permeable fabrics, fabrics with coating (impermeable), fabrics with antibacterial finish, antistatic fabrics  
material composition: 1) 100 % polyester with carbon fibre (< 1%)  
100 % polyester with carbon fibre (< 1%) + polyurethane  
2) 100 % polyester + polyurethane/  
100 % polyester recycled + polyurethane  
3) 100 % polyester + polyvinylchloride  
colour: white, yellow, grey, blue, green, red, black and the other colour tones

This certificate shows the conformity of the product in the assessed parameter with the following technical specification:

- **EN ISO 14644-1:2015 Cleanrooms and associated controlled environments – Part 1: Classification of air cleanliness by particle concentration** (Table No. 1, cleanliness ISO class No. 4)

**Based upon the acquired level of assessed parameter (amount of released particles size 0,5 and 1 µm) the material is classified in cleanliness ISO class No. 4.**

Certification system: Type testing.

The base for the Certificate is the Final Protocol No. COV/23/044-1 from 29.05.2023 and No. COV/23/327 from 03.11.2023 issued by Certification Body Textile Testing Institute in Brno. Final Protocols are the inseparable parts of the Certificate.



Certificate issued:  
Brno 30.05.2023  
Update 06.11.2023  
Validity up to: 31.05.2026



  
Ing. Svatava Horácková  
Head of certification department